

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

The Electrotechnical Testing Institute, the Notified Body 1014 grants the

## CE CONFORMITY CERTIFICATE

with the following European Directives: 2014/30/EU, 2014/35/EU including amendments

No.: 1170230

Name of product: Switchboard for Control system

Type: TR1 (see enclosure)

Rating: 230 V AC, 50 Hz, TN-S, IP44

Ordering firm: UNIS, a.s.  
Jundrovská 1035/33, 624 00 Brno - Komín, Czech Republic

Manufacturer: UNIS, a.s.  
Jundrovská 1035/33, 624 00 Brno - Komín, Czech Republic

Trade mark:

A sample of product was tested and found to be in conformity with following standards:

ČSN EN 61439-1:12 ed.2

ČSN EN 61439-2:12

cl.6.1, 6.2.1, 6.2.2, 6.3, 10.2.2, 10.2.5, 10.2.6, 10.2.7, 10.3, 10.4, 10.5.2, 10.9.2.3 a), b), 10.9.3.3 a), b), 10.10.4, 10.11.2, 10.12

as shown in the Test Report No.: 700839-01/01 ze dne: 27.03.2017

The conformity of product with stated standards implies the conformity of product with principal elements of the above mentioned EU directives.

The validity of the Certificate is limited till: 30.04.2020

05.04.2017

Prague

Mgr. Miroslav Sedláček  
Head of Certification Body



Stamp



700839-01